



NOTES:

1. USE 1" AIR VALVE ASSEMBLIES FOR PIPE ≤ 12", USE 2" AIR VALVE ASSEMBLY ON PIPE > 12".
2. THE DISTANCE BETWEEN RUNGS, CLEATS, AND STEPS SHALL NOT EXCEED 12 INCHES AND SHALL BE UNIFORM THROUGHOUT THE LENGTH OF THE LADDER.
3. LADDER RUNGS ARE REQUIRED IN PRECAST CONC MH.

**JCWSA STANDARD DETAIL C-16
AIR RELEASE VALVE MANHOLE**

SCALE: NTS
DATE OF LAST REVISION: 12/06

