



- NOTES:**
1. RESTRAIN ALL PIPE & FITTINGS SHOWN THIS SHEET.
 2. EXPOSED PIPE AND FITTINGS TO BE FLANGED DUCTILE IRON.
 3. SLOPE FLOOR @ 2% TO 4" FLOORDRAIN AND INSTALL 4" PIPE TO NEAREST STORMDRAIN.
OR
PROVIDE CONCRETE SUMP IN FLOOR AND FLOAT OPERATED SUMP PUMP, PIPE TO NEAREST STORMDRAIN W/2" DRAIN PIPE.

**JCWSA STANDARD DETAIL C-17
DOUBLE CHECK VAULT**

**SCALE: NTS
DATE OF LAST REVISION: 12/06**

