



NOTES

1. MAINTAIN CLEARANCE SUCH THAT VALVE BOX BASE DOES NOT BEAR DIRECTLY ON VALVE BONNET.
2. PROVIDE CONCRETE VALVE MARKER AT ALL VALVES NOT IN PAVEMENT.

**JCWSA STANDARD DETAIL C-7
BURIED GATE VALVE**

**SCALE: NTS
DATE OF LAST REVISION: 12/06**

**JACKSON COUNTY
WATER & SEWERAGE AUTHORITY**

