



NOTES:

1. RESTRAIN ALL PIPE AND FITTINGS SHOWN THIS SHEET.
2. ALL EXPOSED PIPE & FITTINGS ARE FLANGED OR GROOVED.
3. ALL BURIED FITTINGS ARE RJ OR MJ WITH MEGALUGS.

**JCWSA STANDARD DETAIL D-7
SUBMERSIBLE SEWAGE PUMP STATION**

**SCALE: NTS
DATE OF LAST REVISION: 12/06**

**JACKSON COUNTY
WATER & SEWERAGE AUTHORITY**