



**NOTES:**

1. PROVIDE LATCHING DEVICES TO HOLD GATES IN OPEN POSITION.
2. FENCE AND GATE POSTS TO BE GROUNDING WITH 8' X 5/8"φ COPPER CLAD ROD @ 500' INTERVAL AND A BRAIDED COPPER GROUND AT ALL TIMES.

**JCWSA STANDARD DETAIL E-2  
SITE FENCING**

**SCALE: NTS  
DATE OF LAST REVISION: 12/06**

**JACKSON COUNTY  
WATER & SEWERAGE AUTHORITY**